

## AMENDMENT NO.1: Changes to Section V. Schedule of Requirements, Sub-section 3 - Technical Specifications

**BID NO.:** G/OIB/NPWR-06/2024

BID DESCRIPTION: Supply and Delivery of Two (2) Transformer Oil Purification Systems

**DATE:** 16 APRIL 2024

A. This Amendment shall be considered part of the bidding document for the above-mentioned project as though it had been issued at the same time and shall be incorporated integrally therewith. Where provisions of the following supplementary data differ from those of the original bidding document, this Amendment shall govern and take precedence. BIDDERS MUST SIGN THE AMENDMENT AND SUBMIT IT WITH THEIR BIDS.

B. It will be construed that each bidder's proposal is submitted with full knowledge of all modifications and supplementary data specified herein.



Except as described below, the original bidding document remains unchanged. The bid documents are modified and/or clarified, as follows:

## **Amendment 1**

The specifications of the ADDITIONAL VACUUM PUMP and WEATHERPROOF ENCLOSURE have been updated as follows:

Additional Vacuum Pump (integrated within framework)	Vacuum system dedicated only for transformer evacuation. The vacuum system shall comprise of:  Primary vacuum pump: 200 m³/hour capacity Secondary booster pump: 1000 m³/hour capacity  Vacuum system must be fitted with overpressure protection system to protect the transformer against negative pressure and consequent implosion.
Weatherproof Enclosure	Canopy/enclosure providing physical and environmental protection complete with:  Engineered lifting eyes  Multiple doors for ease of operation and maintenance  Extra working lights under canopy/enclosure  All doors fitted with key locks and lift doors fitted with gas struts  Enclosure must have provision or re-sealable opening for power cable entry

BIDDER MUST ACKNOWLEDGE THIS AMENDMENT BY SIGNING BELOW AND <u>ATTACH THE SIGNED AMENDMENT TO THE BID FORMS</u>:

Company Name	
Contact Person	
Signature	
Date	