



**BID NO.:** G/OIB/NPWR-06/2024

**BID DESCRIPTION:** Supply and Delivery of Two (2) Transformer Oil Purification Systems

**DATE:** 11 April 2024

Question no.	Question from Bidders	Answers from NamPower
1.	<p><b>Wednesday, 10 April 2024 08:42</b></p> <p>Could you please clarify the following:</p> <ol style="list-style-type: none"><li>1. Our systems is only suitable for use whilst the transformer is of line due to safety requirements. Would this be acceptable to NamPower?</li><li>2. In line with the above, the oil could be removed from the transformer and purified remotely. Would this be a feasible option?</li></ol> <p>Please keep in mind that our product is locally serviced and supported in Namibia.</p>	<ol style="list-style-type: none"><li>1. A system that only works when the transformer is offline is acceptable to NamPower.</li><li>2. That is a feasible option. However, NamPower will also need to purify the oil on site without removing it from the transformer, especially in emergency situations. The Bidder is advised to take that into consideration.</li></ol>