

CLARIFICATION NO.: 02

BID NO.: G/OIB/NPWR-06/2024

BID DESCRIPTION: Supply and Delivery of Two (2) Transformer Oil Purification Systems

DATE: 15 April 2024

| Question no. | Question from Bidders | Answers from NamPower |
|--------------|---|--|
| 1. | Friday, 12 April 2024 09:07 | |
| | Please advise if the consumables such as filter elements would have to be part of the spares required as per the RFQ? | Filter elements must be part of the required spares. |
| | if so, could you perhaps provide us with an indication of the | We have 100+ transformers and reactors in our network. |
| | amount of transformers as well as the anticipated maintenance frequencies thereof. | The anticipated maintenance frequency will be every six (6) months. |
| 2. | Thursday, 11 April 2024 13:38 | |
| | Question 1. Can we purified on line with VSD control outflow is it acceptable. | Preference is for VSD control at inflow. However, an additional VSD control at outflow is also acceptable. |